



NOTES:

- NO FIRE HYDRANT EXTENSIONS ARE ALLOWED.
- BOLT TORQUE ON ALL FITTINGS SHALL CONFORM TO MANUFACTURER'S SPECIFICATIONS.
- AREA AROUND FIRE HYDRANT SHALL BE COMPACTED TO 90% MINIMUM.
- PAINT HYDRANT BURY USING A MANUFACTURER'S RECOMMENDED PRIMER, FINISH WITH RUSTOLEUM GLOSS WHITE, TWO COATS MINIMUM. PRIOR TO PAINTING, CLEAN ALL SURFACES WITH SOAP AND WATER USING AN ABRASIVE PAD.

1	TEE - DUCTILE IRON - FLANGED OUTLET	7	VALVE BOX/LID - MARKED "WATER", DLDCASTLE PRECAST NO. G04 BOX, G04C LID
2	6" GATE VALVE - RESILIENT WEDGE - FLANGED TO TEE x MECHANICAL JOINT	8	CONCRETE ENCASUREMENT AROUND VALVE BOX - TYPE II SIX-SACK PORTLAND CEMENT - SEE DETAIL VB_811
3	6" DUCTILE IRON PIPE - PC350	9	#10 INSULATED COPPER LOCATOR WIRE
4	STEAMER FIRE HYDRANT - MUELLER A-423 OR AMERICAN DARLING B84B - MINIMUM 54" BURY, MECHANICAL JOINT INLET. SHALL BE FACTORY WHITE.	10	CONCRETE BRICK - 2 1/4" x 3 3/4" x 7 1/2"
5	BRASS PLUGS SHALL BE INSTALLED IN DRAIN HOLES IN SHOE.	11	CONCRETE THRUST BLOCK - SEE DETAIL TB_001
6	8" RISER - SDR35 ONLY, CONTINUOUS SECTION	12	BLUE REFLECTIVE MARKER - INSTALLED PER SACRAMENTO METROPOLITAN FIRE DISTRICT SPECIFICATIONS



**CITRUS
HEIGHTS
WATER
DISTRICT**

FIRE HYDRANT - 6" CONNECTION (PLANTER AREA)

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: Robert A. Chubb DATE: 5/8/13
CITRUS HEIGHTS WATER DISTRICT

DETAIL FOR CONSTRUCTION IN:
SACRAMENTO METRO FIRE DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: FH_617.DWG

PAGE:

FH_617