



NOTE:

1. AN 18 FOOT LENGTH OF PC350 DUCTILE IRON PIPE (DIP) OR A 20 FOOT LENGTH OF CL305 DR 14 AWWA C900-07 POLYVINYLCHLORIDE (PVC) WATER MAIN TO BE CENTERED BELOW SEWER OR STORM DRAIN CROSSINGS.



## SEWER/STORM CROSSING DETAIL

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

*Robert A. Chamberlain*

CITRUS HEIGHTS WATER DISTRICT

DATE: 5/8/13

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN\_782.DWG

PAGE:

TREN\_782