



NOTES:

- RISER SHALL BE PLUMB.
- VALVE OPERATING NUT SHALL BE CENTERED IN THE RISER AND FULLY ACCESSIBLE.
- MATERIAL BELOW AGGREGATE BASE SHALL BE COMPACTED TO 90% MINIMUM.
- CONTACT CITRUS HEIGHTS WATER DISTRICT FOR REBAR INSPECTION PRIOR TO POURING CONCRETE. (916) 725-6873
- REINFORCED CONCRETE PAD SHALL BE FINISHED WITH AN EDGING TOOL AROUND THE ENTIRE PERIMETER AND BROOMED AT RIGHT ANGLES TO THE DIRECTION OF TRAVEL.
- TRIANGULAR LID SHALL POINT IN THE DIRECTION OF THE MAIN WHICH IS ISOLATED BY THE VALVE.

1	VALVE BOX/LID - MARKED "WATER", OLDCASTLE PRECAST NO. G04 BOX, G04C LID	5	3/4" CLASS 2 AGGREGATE BASE - 2" MINIMUM, MECHANICALLY COMPACTED TO 90%
2	8' RISER - SDR35 ONLY, CONTINUOUS SECTION	6	CONCRETE DOBIE w/ WIRE
3	#10 INSULATED COPPER LOCATOR WIRE	7	3/8" (#3) REBAR - 2" INSIDE PERIMETER
4	REINFORCED CONCRETE PAD - 4' THICK x 30' SQUARE, TYPE II SIX-SACK PORTLAND CEMENT		



**CITRUS
HEIGHTS
WATER
DISTRICT**

WATER MAIN VALVE BOX - LANDSCAPE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: *Robert A. Chamberlain* DATE: 5/8/13
 CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: VB_810.DWG

PAGE:

VB_810