



1	1' BRONZE SADDLE - IPT	4	1' BRASS COUPLING AS REQUIRED TO CONNECT TO EXISTING 1' WATER SERVICE
2	1' CORPORATION STOP - FULL-PORT BALL, MIP xCTS COMP		
3	1' COPPER TUBING - TYPE K SOFT	5	#2 WASHED SAND COMPACTED TO 90%



**CITRUS
HEIGHTS
WATER
DISTRICT**

1" COPPER WATER SERVICE SADDLE REPLACEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE: 9/25/14

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_109CU.DWG

PAGE:

WS_109CU