



CARSON 1220-4B "T" TYPE LID:

SHALL INCLUDE STRAIGHT TYPE HEXAGON LOCK-DOWN BOLT (1) AND TOUCH READ HOLE. SHALL BE MARKED "WATER"

CHRISTY FL36P RECESSED LID:

SHALL INCLUDE STRAIGHT TYPE PENTAHEAD LOCK-DOWN BOLTS (2) AND NEPTUNE OFFSET AMR HOLE, SHALL BE MARKED "WATER"

METER YOKE:

FORD, JONES, MUELLER, McDONALD

1	2" BRONZE SADDLE - IPT	10	2" COPPER/BRASS METER YOKE - 12" w/2 FULL-PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET
2	2" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (2" CTS INSERT-55-Q)	11	2" WATER METER (BY DISTRICT)
3	2" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SDDR 9 (250 PSI) OR EQUAL	12	2" METER FLANGES AND IDLER (BY CONTRACTOR)
4	2" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (2" CTS INSERT-55-Q)	13	2" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)
5	2" BRASS STREET ELBOW	14	2" PVC COUPLING - SCH 80
6	2" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP w/ STAINLESS STEEL INSERT (2" CTS INSERT-55-Q)	15	METER BOX
7	2" BRASS NIPPLE (AS NECESSARY TO ADJUST TO PROPER GRADE)	16	LID
8	2" BRASS UNION	17	2" x 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
9	2" x CLOSE BRASS NIPPLE	18	3/4" CLEAN CRUSHED ROCK
		19	#2 WASHED SAND COMPACTED TO 90%
		20	#10 INSULATED COPPER LOCATOR WIRE

**2" POLYETHYLENE WATER SERVICE - 2" WATER METER
NEW CONSTRUCTION**

CITRUS HEIGHTS WATER DISTRICT



**CITRUS
HEIGHTS
WATER
DISTRICT**

APPROVED BY: *Melina Pierri*

CITRUS HEIGHTS WATER DISTRICT

DATE: APRIL 15, 2021

DRAWN: 25 SEP 2014

REVISED: 15 ADR 2021

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_200PE.DWG

PAGE: **WS_200PE**